

Division 9 Resilient Athletic Flooring TRACKDECK 8mm- ROLLED RUBBER FLOORING

Specifier Note: The following CS/ (Construction Specifications / Institute) section describes the resilient athletic flooring system to be installed on the specific project. The number and title of the section may be changed if the Specifier deems necessary; but in any circumstance it will belong to the general CS/ Section 09 65 00: Resilient Flooring.

PART 1 - GENERAL

1.1 SUMMARY

- A. Products Supplied
 - 1. Resilient (rubber) athletic flooring.
 - 2. Adhesive and accessories required for installation, maintenance and repair.
- B. Related Requirements
 - 1. Section 02 25 00 - Existing Material Assessment
 - 2. Section 03 05 00 - Common Work Results for Concrete
 - 3. Section 06 05 00 - Common Work Results for Wood, Plastics, and Composites
 - 4. Section 07 05 00 - Common Work Results for Thermal and Moisture Protection
 - 5. Section 07 10 00 - Dampproofing and Waterproofing

Specifier Note: The CS/ sections of the project manual are a guide to what is the essential information needed to determine the acceptability of the site conditions and details of the installation of TrackDeck product by California Sports Surfaces. The Specifier may choose to include other sections he/she deems necessary.

1.2 REFERENCES

- A. American Society for Testing & Materials (ASTM)
 - 1. ASTM D2047: Standard Test Method for Static Coefficient of Friction of Polish-Coated Floor Surfaces as measured by the James Machine.
 - 2. ASTM D2240: Standard Test Method for Rubber Property (Durometer Hardness).
 - 3. ASTM D5116: Standard Guide for Small-Scale Environmental Chamber Determinations of Organic emissions from Indoor Materials/Products.
 - 4. ASTM E648: Standard Test Method for Critical Radiant Flux of Floor Covering Systems Using a Radiant Heat Energy Source.
 - 5. ASTM E662: Standard Test Method for Specific Optical Density of Smoke Generated by Solid Materials.
 - 6. ASTM E1745: Standard Specification for Water Vapor Retarders Used in Contact with Soil or Granular Fill under Concrete Slabs.
 - 7. ASTM F970: Standard Test Method for Static Load Limit.



8. ASTM F1869: Standard Test Method for Measuring Moisture Vapor Emission Rate of Concrete Subfloor Using Anhydrous Calcium Chloride.
9. ASTM G21: Standard Practice for Determining Resistance of Synthetic Polymeric Materials to Fungi.
10. ASTM F710: Standard Practice for Preparing Concrete Floors to Receive Resilient Flooring.
 - a. National Fire Protection Association
 1. NFPA 101: Life Safety Code[®].

1.3 SUBMITTALS

Specifier Note: The following are typical submittals. The Specifier may choose to include other submittals he/she deems necessary.

- A. Action Submittals
 1. Provide Manufacturer's current printed data sheets on specified products (flooring, adhesives, accessories, etc.).
 2. Provide shop drawings prepared for project illustrating layouts, details, dimensions and other data.
 3. Provide samples for verification of such characteristics as color, texture and finish.
- B. Informational Submittals
 1. Provide Manufacturer's current installation guidelines as published by the Manufacturer.
- C. Closeout Submittals
 1. Provide Manufacturer's current maintenance guidelines as published by the Manufacturer.
 2. Provide Manufacturer's current standard warranty as published by the Manufacturer.
- D. Maintenance Material Submittals
 1. Provide extra stock materials for use in facility operation and maintenance. Provide amount of approximately 2% of the total floor surface, of each type, color and dye lot.

1.4 QUALITY ASSURANCE

- A. Manufacturer must be certified ISO 9001.
- B. Manufacturer must have experience in the manufacturing of prefabricated rubber athletic flooring.
- C. Installer must have performed installations of the same scale in the last three (3) years.
- D. Installer to be recognized and approved by the rubber athletic flooring Manufacturer.
- E. Installation of mock-up is highly recommended and must be deemed acceptable by Owner and Architect. Mock-up is to be installed following the same procedures and utilizing the same specified materials that will be used for the actual project. - Mock-up size: [XX" x XX" (XX cm x XX cm)].



Specifier Note: Specify mock-up dimensions as instructed by Owner or Architect.

1.5 DELIVERY, STORAGE AND HANDLING

- A. Maintain a stable room and subfloor temperature for a period of 48 hours prior, during and 48 hours after installation. Recommended range: 65 degrees F to 86 degrees F.
- B. Installation to be carried out no sooner than the specified drying time of concrete subfloor (normal density concrete drying time is approximately 90-120 days for proper adhesion of resilient flooring).
- C. Moisture vapor emission content of the concrete slab must not exceed the tolerance of the adhesive used when tested using the anhydrous calcium chloride test as per ASTM F1869.
- D. Installation of rubber athletic flooring will not commence unless all other trades in the building are completed.

1.6 SITE CONDITIONS

- A. Maintain a stable room and subfloor temperature for a period of 48 hours prior, during and 48 hours after installation. Recommended range: 65 degrees F to 86 degrees F.
- B. Installation to be carried out no sooner than the specified drying time of concrete subfloor (normal density concrete drying time is approximately 90-120 days for proper adhesion of resilient flooring).
- C. Moisture vapor emission content of the concrete slab must not exceed the tolerance of the adhesive used when tested using the anhydrous calcium chloride test as per ASTM F1869.
- D. Installation of rubber athletic flooring will not commence unless all other trades in the building are completed.

1.7 WARRANTY

- A. Provide Manufacturer's current standard warranty.
- B. The rubber athletic flooring is warranted to be free from manufacturing defects for a period of three (3) years from the date of shipment from the Manufacturer.
- C. The rubber athletic flooring is warranted against excessive wear under normal usage for a period of five (5) years from the date installation.



PART 2 - PRODUCT

2.1 MANUFACTURED PRODUCTS

- A. Address: California Sports Surfaces
150 Dascomb Rd., Andover, MA 01810
Telephone: 800-364-0287
Email: sportorders@icpgroup.com

2.2 PROPRIETARY PRODUCTS

- A. TrackDeck rolled rubber and adhesives manufactured by California Sports Surfaces for indoor commercial and athletic applications.
1. TrackDeck 8mm rolled rubber
 2. SignaGrip, a one-compound polyurethane adhesive

2.3.1 TRACKDECK 8MM ROLLED RUBBER SPECIFICATIONS

- A. Product Name: The rubber surfacing system furnished under this specification shall be RubberDeck Elite rolled rubber.
- B. Material: TrackDeck is a prefabricated rubber athletic flooring, having a surface layer of 100% EPDM laminated to a 100% recycled rubber underlayment as manufactured by California Sports Surfaces. Manufactured in two layers which are laminated together. The shore hardness of the top layer will be greater than that of the bottom layer; shore hardness of layers to be recommended by the manufacturer and the limits specified.
- C. Roll Width: 4' wide
- D. Roll Length: Custom
- E. Color: Available in 33 colors (6 standard)
- F. Thickness: 8mm (4mm surface + 4mm underlayment)
- G. Finish: Smooth/Matte



Specifier Note: Specify color, size and thickness of product used in project.

Performance of the prefabricated rubber athletic flooring to conform to the following criteria:

H.	Tensile Strength:	>200 (ASTM D 412)
I.	Flexibility ¼" mandrel:	PASS (ASTM F 137)
J.	Thermal Conductivity:	>0.4 (ASTM C 518)
K.	Static Load Limit:	<0.02 (ASTM F 970)
L.	Fungal Resistance Test:	NO GROWTH (ASTM G 21-90)
M.	Coefficient of Friction:	>0.9 (ASTM D 2047)
N.	V.O.C Compliant:	YES (ASTM D 5116)
O.	Color Stability:	GOOD
P.	Light Reflection:	GOOD
Q.	Chemical Resistance:	GOOD

2.3.2 SIGNAGRIP ONE-COMPONENT POLYURTHANE ADHESIVE

A.	Product Name:	The one-part urethane adhesive under this specification shall be SignaGrip one-component polyurethane adhesive.
B.	Material:	SignaGrip is a one-component polyurethane moisture cured, non-sag, permanently elastic adhesive that has excellent adhesion to elastomers, concrete and wood and is engineered for indoor and outdoor applications.
C.	Adhesive Type:	One-component polyurethane
D.	Adhesive Cure System:	Moisture cured



TRACKDECK[™] HIGH PERFORMANCE ROLLED RUBBER FLOORING

E.	Weight:	4 gallon pail - 56 lbs 2 gallon pail - 28 lbs 10.1 oz. cartridge
F.	Color:	Medium grey
G.	VOC Content:	0 (calculated)
H.	Solvents:	None
I.	Freeze/Thaw:	Stable
J.	Application Temperature:	40°F to 100°F
K.	Calcium Chloride Test allowable:	Maximum 5.5 lbs per 1,000 sq. ft. in 24 hrs (ASTM F1869)
L.	Flashpoint:	> 500° F
M.	Shelf Life:	12 months
N.	Working Time:	30-40 minutes
O.	Trowel:	1/16" square notched trowel ⁽¹⁾
P.	Coverage Rate:	95 ft ² per gallon (1/16" square notched trowel)
Q.	SCAQMD Rule #1168:	0 (calculated)

⁽¹⁾ For indoor installation on concrete or plywood subfloors only. See California Sports Surfaces Installation Manual for instructions.

2.4 MATERIALS

- A. Provide TrackDeck prefabricated rubber athletic flooring manufactured by California Sports Surfaces.
- B. Provide rubber athletic surface as specified in section 2.1.2 Description.



2.5 ACCESSORY PRODUCTS

- A. Provide adhesive certified by the Manufacturer: SignaGrip (refer to instruction manual of adhesives provided by rubber athletic flooring Manufacturer).
- B. Patching or leveling compound to be supplied and/or recommended/approved by rubber athletic flooring Manufacturer.
- C. Gameline paint products to be supplied and/or recommended/approved by rubber athletic flooring Manufacturer.

Specifier Note: accessories should be specified in accordance with the project requirements

PART 3 - EXECUTION

3.1 INSTALLERS

- A. Refer to section 1.4 of this document for information on installers.

3.2 EXAMINATION

Specifier Note: the following must be ensured prior to installation of the primary product.

- A. Concrete or asphalt subfloors to be placed a minimum of twenty-eight (28) days prior to installation of rubber athletic flooring.
- B. Concrete or asphalt subfloors on or below grade are installed over a suitable moisture retardant membrane. Water vapor membrane complies with specification in ASTM E1745.
- C. No concrete or asphalt sealers or curing compounds are applied or mixed with the subfloors (refer to Section 03 05 00 - Common Work Results for Concrete of Division 3).
- D. The underlayment is adequate (if installing over wood subfloors, California Sports Surfaces only recommends APA (Engineered Wood Association) Exterior grade plywood or CANPLY Exterior Certified plywood (Group 1, CC type).
- E. Moisture and alkalinity tests must be performed. Moisture content must not exceed the capacity of the specified adhesive (verify using the anhydrous calcium chloride test as per ASTM F1869) and pH level should be in the range of 7 to 8.5.
- F. Smooth, dense finish, highly compacted with a tolerance of 1/8" in a 10 ft radius (3.2 mm in 3.05m radius). Floor Flatness (FF) and Floor Levelness (FL) numbers are not recognized.



3.3 PREPARATION

Specifier Note: Subfloors are to be prepared according to Manufacturer's written instructions. /t is recommended that the Specifier review the preparation process from the Manufacturer's printed recommendations given to him/her by the Technical Department of California Sports Surfaces. The following are considered common practice subfloor preparation to receive floor finishing products, and as such, should not be omitted or altered in any case.

- A. Prepare subfloor in accordance with Manufacturer's current printed Subfloor Preparation guidelines

3.4 INSTALLATION

Specifier Note: Products are to be installed according to Manufacturer's written instructions. /t is recommended that the Specifier review the installation process from the Manufacturer's printed installation manual or from the installation procedures given to him/her by the Technical Department of California Sports Surfaces. The following procedures may be altered in special project cases, as deemed necessary by the Specifier, and after having consulted the Technical Department of California Sports Surfaces.

- A. Installation of Sheet Goods
 - 1. Install rubber athletic flooring in accordance with Manufacturer's current printed installation Manual.

3.5 REPAIR

- A. Refer to section 1.3.4 for extra stock materials.
- B. Repair material must be from the same dye lot as material supplied for initial installation
- C. Repairs are to be performed by qualified installers/technicians only.

3.6 CLEANING

- A. Initial cleaning should only be performed 72 hours after the rubber athletic surface has been completely installed.
- B. Maintain rubber athletic flooring according to Manufacturer's current maintenance instructions for specified product.

3.7 PROTECTION

- A. Rubber athletic flooring surface can be protected with Masonite during and after the installation, prior to acceptance by the Owner.